

**Title:**

CLASSIFICATION OF  
REACTION TO FIRE  
PERFORMANCE  
IN ACCORDANCE WITH  
EN 13501-1:2007+A1: 2009.

**Notified Body No:**

0833

**Product Name:**

"Aluminance A2 Composite  
Panel"

**Report No:**

WF 404351

**Issue No:**

1

**Prepared for:**

Zahit Alüminyum San. Ve Tic  
A.Ş.,  
Hacı Sabancı Organize Sanayi  
Bölgesi Oğuz Kağan Köksal  
Cad. No:5 SARIÇAM / ADANA  
/ TÜRKİYE

**Date:**

23<sup>rd</sup> January 2019



#### 4. Classification and field of application

##### 4.1 Reference of classification

This classification has been carried out in accordance with clause 8 of EN 13501-1:2007+A1:2009.

##### 4.2 Classification

The product, "Aluminance A2 Composite Panel", a coated aluminium composite panel, in relation to its reaction to fire behaviour is classified:

**A2**

The additional classification in relation to smoke production is:

**s1**

The additional classification in relation to flaming droplets / particles is:

**d0**

The format of the reaction to fire classification for construction products excluding flooring and linear pipe thermal insulation is:

Fire Behaviour		Smoke Production			Flaming Droplets	
A2	-	s	1	,	d	0

i.e. A2 – s1 , d0

**Reaction to fire classification: A2-s1, d0**